



18 Dec. 09

**Incident Observed at PSO House – Lesson Learned Document**

A Fire incident has been observed in PSO House at 5<sup>th</sup> Floor, Electric kettle kept on the carpet caught fire during and after boiling of water for tea when it was left unattended after office hours and was not plugged out.

All are requested to please switch off the electric appliances after use and electric kettle should be place at pantry in designated area. Also, concerned staff needs to be aware in this regard.

**Pictorial View of Incident Site**



Burned Electric Kettle



Burned Electric Kettle



Undesignated area for Electric Kettle.



Condition of carpet after incident

**“Stay Alert and Be Safe”**